

**Southwestern Power Administration
17-Reservoir System Spilled Energy Due to Forced Outages**

Spilled Energy (MWh)	FY'04	FY'05	FY'06	FY'07	FY'08	TOTAL
Ozark	87,600	208,300	18,800	80,000	133,200	527,900
Webbers Falls	18,400	88,600	7,800	179,000	108,800	402,600
SubTotal	106,000	296,900	26,600	258,900	242,000	930,400
Truman	0	0	0	29,400	1,300	30,700
Stockton	0	0	0	0	9,700	9,700
RS Kerr	100	10,100	0	700	0	10,900
Dardanelle	100	0	0	0	0	100
Keystone	0	1,700	0	0	0	1,700
Fort Gibson	0	900	0	1,400	0	2,300
SubTotal	200	12,600	0	31,500	11,000	55,300
TOTAL	106,200	309,500	26,600	290,400	253,000	985,700

Estimated Value¹ (\$)	FY'04	FY'05	FY'06	FY'07	FY'08	TOTAL
Ozark	2,933,000	9,449,000	869,000	4,114,000	7,872,000	25,237,000
Webbers Falls	687,000	4,102,000	362,000	9,260,000	6,379,000	20,790,000
SubTotal	3,620,000	13,551,000	1,230,000	13,373,000	14,251,000	46,025,000
Truman	0	0	0	1,473,000	94,000	1,567,000
Stockton	0	0	0	0	576,000	576,000
RS Kerr	4,000	711,000	0	27,000	0	742,000
Dardanelle	4,000	0	0	0	0	4,000
Keystone	0	86,000	0	0	0	86,000
Fort Gibson	0	39,000	0	71,000	0	110,000
SubTotal	7,000	837,000	0	1,570,000	670,000	3,084,000
TOTAL	3,627,000	14,388,000	1,230,000	14,944,000	14,921,000	49,110,000

¹ Estimated value based on off/on peak monthly prices from Platts Megawatt Daily for the SPP region.

Note: Spilled energy amounts are computed from spilled water volumes using normal headwater and tailwater conditions. No evaluation of the feasibility or even possibility of producing the indicated energy in a given month was made.